



Product Service

Attestation of Conformity

No. N8A 096025 0003 Rev. 00

Holder of Certificate: Equipaggiamenti
Electronici Industriali S.p.A.
Viale dell'Industria 37
36100 VICENZA
ITALY

Product: Converter
(Hybrid inverter)

This Attestation of Conformity is issued on a voluntary basis according to the Low Voltage Directive 2014/35/EU relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the directive and is based on the technical specifications applicable at the time of issuance. It refers only to the particular sample submitted for testing and certification. For details see: www.tuvsud.com/ps-cert

Test report no.: 64290203044201A

Date, 2020-12-02

(Billy Qiu)

Page 1 of 3

After preparation of the necessary technical documentation as well as the EU declaration of conformity the required CE marking can be affixed on the product. The declaration of conformity is issued under the sole responsibility of the manufacturer. Other relevant EU-directives have to be observed.



Attestation of Conformity

No. N8A 096025 0003 Rev. 00

Model(s): E-CASA 3.6 HU, E-CASA 5.0 HU, E-CASA 6.0 HU

Parameters:

Model	E-CASA 3.6 HU	E-CASA 5.0 HU	E-CASA 6.0 HU
PV terminal			
Vmax. PV	580Vd.c.		
Rate Voltage	400Vd.c.		
MPPT Voltage Range	120~550Vd.c.		
MPPT Voltage Range (full load)	184 ~ 550Vd.c.	230 ~ 550Vd.c.	300 ~ 550Vd.c.
MPPT Tracker number	2		
Max. continuous PV input current per tracker	13Ad.c.		
Isc PV per tracker	16Ad.c.		
Max. continuous PV input power	4800W	6500W	7500W
Battery terminal			
Battery type	Lithium or lead-acid batteries		
Voltage range	40~60Vd.c.		
Rated voltage	48Vd.c.		
Maximum charge/discharge current	50Ad.c./80Ad.c.	100Ad.c./100Ad.c.	
Maximum charge/discharge power	3000W/4000W	4600W/5000W	
Grid terminal parameter			
Rated voltage	230Va.c.		
Rated frequency	50Hz		
Rated input Current	31Aa.c.		
Maximum continuous input current	32Aa.c.		
Maximum continuous input power	7360VA		
Rated output Current	16Aa.c.	22Aa.c.	25Aa.c.
Maximum continuous output current	16Aa.c.	22Aa.c.	25Aa.c.
Power factor (Cos phi), adjustable	0.9 leading ~0.9 lagging		
Maximum continuous output power	3680VA	5000VA	6000VA
Back up load terminal parameter			
Rated voltage	230Va.c.		
Rated frequency	50Hz		
Rated output Current	16Aa.c.	20Aa.c.	
Maximum continuous output current	16Aa.c.	20Aa.c.	
Rated continuous output power	3680W	4600W	
Maximum output apparent power	4000VA	5000VA	
General parameter			
Temperature	-25°C to +60°C		
Protective class	Class I		
Overvoltage Category	II(DC side), III(AC side)		
Ingress protection	IP65		

Page 2 of 3

After preparation of the necessary technical documentation as well as the EU declaration of conformity the required CE marking can be affixed on the product. The declaration of conformity is issued under the sole responsibility of the manufacturer. Other relevant EU-directives have to be observed.



Product Service

Attestation of Conformity

No. N8A 096025 0003 Rev. 00

**Tested
according to:**

EN 62109-1:2010
EN 62109-2:2011

Page 3 of 3

After preparation of the necessary technical documentation as well as the EU declaration of conformity the required CE marking can be affixed on the product. The declaration of conformity is issued under the sole responsibility of the manufacturer. Other relevant EU-directives have to be observed.