

Compliance Document

No. D 096025 0004 Rev. 00

Holder of Certificate: **Equipaggiamenti
Elettronici Industriali S.p.A.**
Viale dell'Industria 37
36100 VICENZA
ITALY

Product: **Converter
(Hybrid Inverter with storage battery
system)**

This Compliance document confirms the compliance with the listed standards on a voluntary basis. It refers only to the sample submitted for testing and certification and does not certify the quality or safety of the serial products. For details see: www.tuvsud.com/ps-cert

Test report no.: 64290203050501A

Date, 2020-12-07



(Billy Qiu)

Compliance Document

No. D 096025 0004 Rev. 00

Model(s): Inverter models: **E-CASA 3.6 HU,**
E-CASA 5.0 HU
 Battery model: **E-CASA 5.1 BU**

Parameters:

Model	E-CASA 3.6 HU	E-CASA 5.0 HU
PV input rating		
Max. input power	4800 W	6500 W
Rated input voltage	400 Vd.c.	400 Vd.c.
Max. input voltage	580 Vd.c.	580 Vd.c.
MPPT voltage range	184 - 550 Vd.c.	230 - 550 Vd.c.
Max. input current	13 Ad.c.×2	13 Ad.c.×2
PV short circuit current	16 Ad.c.×2	16 Ad.c.×2
Battery input/output rating		
Battery type	LFP (LiFePO4)	LFP (LiFePO4)
Rated voltage	48 Vd.c.	48 Vd.c.
Battery voltage range	40 - 60 Vd.c.	40 - 60 Vd.c.
Max. charging power	3000 W	4600 W
Max. charging current	50 Ad.c.	100 Ad.c.
Max. discharging power	4000 W	5000 W
Max. discharging current	80 Ad.c.	100 Ad.c.
Grid input rating		
Rated input voltage	230 Va.c.	230 Va.c.
Rated grid frequency	50 Hz	50 Hz
Max. input apparent power	7360 VA	7360 VA
Max. input active power	7360 W	7360 W
Max. input current	32 Aa.c.	32 Aa.c.
Grid output rating		
Max. output apparent power	3680 VA	5000 VA
Max. output active power	3680 W	5000 W
Rated output voltage	230 Va.c.	230 Va.c.
Max. output current	16 Va.c.	22 Va.c.
Rated output frequency	50 Hz	50 Hz
Power factor	0.9 leading - 0.9 lagging	0.9 leading - 0.9 lagging
AC load output rating		
Max. output apparent power	4000 VA	5000 VA
Max. output active power	3680 W	4600 W
Rated output voltage	230 Va.c.	230 Va.c.
Max. output current	16 Aa.c.	20 Aa.c.
Rated output frequency	50 Hz	50 Hz

Compliance Document

No. D 096025 0004 Rev. 00

Battery model	E-CASA 5.1 BU			
Manufacturer	Equipaggiamenti Elettronici Industriali S.p.A.			
Battery type	Lithium			
Rated voltage	51.2 Vd.c.			
Capacity of battery[kWh]	5.12(with 1× battery unit)	10.24(with 2× battery unit)	15.36(with 3× battery unit)	20.48(with 4× battery unit)
Firmware version of the BMS	V1.0.0			

TYPE OF APPARATUS:

DISCONNECTION DEVICE	INTERFACE PROTECTION DEVICE	DEVICE FOR STATIC CONVERSION	ROTATING GENERATOR DEVICE
X	X	X	

Manufacturer: Equipaggiamenti Elettronici Industriali S.p.A.

Apparatus type: Hybrid Inverter with storage battery system

Model: See page 2

Firmware version: V1.0.0

Number of phase: 1

Nominal power: See above tables

Remark: The devices are capable to limit I_{dc} to 0.5% of the rated grid current

Having assessed the test report:

64.290.20.30505.01A dated 03.12.2020

Issued by laboratory:

TÜV SÜD Certification and Testing (China) Co., Ltd. Guangzhou Branch
5F, Communication Bldg., 163 Pingyun Road, Huangpu West Ave, Guangzhou city 510656,
P.R.China

Laboratory Accredited by DAkkS

In compliance with ISO/IEC 17025:2005

Accreditation number: D-PL-19065-01-00

Having examined the ISO 9001 certificate of production facility, number
NO: HK03/0243

Issued by:

CEPREI Certification Body (Management system CNAS C012-M)

Tested according to:

CEI 0-21:2019